

Enveloppe vide pour appareils d'éclairage - Série FD
Empty enclosure for lighting fixture - Series FD

	Equipement / Equipment	I/2 G	I/2 D
	Niveau de protection / Protection level	/	/
	Mode de protection / Protection mode	*	**
	Température de service / Service temperature	- 20°C ≤ Ta ≤ + 85°C	
	Classe de température / Temperature class	/	/
	Température de surface / Surface temperature	/	/
	Certificat ATEX / ATEX Certificate	LCIE 13 ATEX 3080U	
	Certificat CEI / IEC Certificate	/	
	Codes IP & IK / IP & IK Codes	IP66 / 67 (1)	

(1) IP66 Sans joint torique / IP66 without O ring gasket

Type	Longueur A (mm) Length A (mm)	Gas *	Poussières ** Dust	Volume interne (cm³) Internal volume (cm³)
FDU400...	430	Ex db IIC	Ex tb IIIC	4600
FDU440...	470	Ex db IIC	Ex tb IIIC	4940
FDU710...	745	Ex db IIC	Ex tb IIIC	8100
FDU1320...	1365	Ex db IIB + H2	Ex tb IIIC	15000
FDU1620...	1655	Ex db IIB	Ex tb IIIC	18500

UTILISATION - USE

FR Cet appareil est considéré comme un composant et n'a pas de fonction autonome. Il est conçu pour fonctionner dans toutes les positions.
La température maximale admissible du scellement (entre tube de verre et les deux embouts d'extrémité) est de 85°C quelle que soit la température ambiante à laquelle le produit sera soumis.
La certification tierce partie du produit fini est obligatoire.

GB This apparatus is considered as a component and has no autonomous function. It is designed to operate in all positions.
The maximum service temperature permitted on the cement (between the glass tube and the two end caps) is 85°C whatever the ambient temperature at which the finish product will be subjected.
The third party certification of the final product is mandatory.

VUE D'ENSEMBLE - MAIN VIEW

